

**Memo**



**Stantec**

To: Stu White  
Banwell Architects

From: Robert F Kischko  
North Springfield VT

File: 1957100053

Date: September 27, 2006

---

**Reference: Green Woodlands – Addenda 2 (Electrical)**

This addendum forms a part of the Contract Documents and modifies the original Specifications dated August 31<sup>st</sup> (Addendum No. 1) Bidders must acknowledge receipt of this addendum in the space provided on the Bid form. **Failure to do so may subject the Bidder to disqualification.**

This addendum to the Contract Documents consists of 1 page.

**The Contract Documents are amended as follows:**

1. Drawing E1.02 – delete a total of 6 telephone receptacles in the bedrooms – 2 each bedroom. Coordinate with Owner/Architect on exact location of telephone outlet to remain. Bedroom 08 will have 2 outlets, bedroom 10 and 13 shall only have one.
2. Drawing E1.02 – Add circuit for the 1/3 HP motor for wood dumbwaiter, see Architectural plans for locations. Provide wiring and all related devices as per manufacturers instructions. Circuit AC-37, 3/4" conduit with 2#10, 1#10G.
3. Contractor shall carry an allowance of \$15,000 (fifteen thousand dollars) for an Energy Interface Controller and related wiring to coordinate the hydro, solar (battery charger function) and generator.