



6" COMPOSITE NAIL BASE INSULATION - SEE SPEC  
 STANDING SEAM ON FULL COVERAGE ICE & WATER SHIELD  
 ROOF EDGE TO BE A 8" S.I.P. TO MATCH COMPOSITE NAIL BASE INSULATION THICKNESS

1-1/2" POLYISOCYANURATE INSULATION R-6.25 PER INCH

CONDUIT ON TOP OF BEAM FOR PENDANT LIGHTS  
 1-1/2" WOOD DECKING

SPRAY FOAM SEALED TO ROOF INSULATION

TOP OF WALL 127'-2"  
 METAL ROOF EDGE

NAIL BASE BOARD SOFFIT

2X3 NAILER 2' O.C.

04 ROOF EDGE DETAIL  
 SCALE: 1 1/2"=1'-0"

2ND FLR. ELEV. 119'-7 1/2"

03 FLOOR EDGE DETAIL  
 SCALE: 1 1/2"=1'-0"

CONDUIT RUN

POST BEYOND

3/4" SHIP LAP SIDING  
 HOME SLICKER BY BENJAMIN OBDYKE OVER 15# BUILDING FELT

3/4" DIAGONAL SHEATHING

(4 1/2" NOM.) SPRAY FOAM INSULATION SYSTEM

5" WOOD STUDS 2' O.C.  
 2X3 NAILER 2' O.C.

1ST FLR. ELEV. 110'-6 1/4"

RETROFITTED FILT HVA ADHESIVE ANCHORS  
 P.T. SILLS: BORATE TREATED

BC65 EPDM STRUCTURAL GASKETS BY RESOURCE CONSERVATION TECHNOLOGY

GALV. ANGLE UNDER EPDM GASKET  
 6" WIDE SCREEN STRIP FOLDED IN HALF. TYP. @ BOTTOM OF SIDING

"DURISOL" REINFORCED, INSULATED, FOUNDATION UNITS.  
 ENGINEERING BY MANUFACTURER

PARGE COAT EXTERIOR OF DURISOL TOP OF FOUN. WALL

108'-10" (DWG. C-1 REF: 1001'-6")  
 2" GRANITE

WARM-N-DRI 1-3/16" RIGID FIBERGLASS BOARD  
 TUFF-N-DRI FLUID APPLIED ADHESIVE WATERPROOFING- CONNECTING FOUNDATION INSUL TO SPRAY FOAM INSULATION SYSTEM

107'-8" (DWG. C-1 REF: 1000'-4")  
 6" X 3 1/2" X 1/2" GALV. ANGLE  
 1/2" BOLT EMBEDDED 8" IN CONCRETE SPACED @ 24" O.C.  
 REMOVE 6"x6" SQUARE OF DURISOL AT EACH BOLT LOCATION

02 TOP OF FOUNDATION DETAIL  
 SCALE: 1 1/2"=1'-0"  
 BASEMENT ELEV. 100'-0" (DWG. C-1 REF: 992'-8")

FLUID APPLIED ADHESIVE WATERPROOFING

FILTER FABRIC  
 STONE  
 4" DIA. PERFORATED FOOTING DRAIN

01 BOTTOM OF FOUNDATION DETAIL  
 SCALE: 1 1/2"=1'-0"

5/8" WOOD STRIP  
 1/2" GWB W/ 1/8" PLASTER SKIM COAT

1" FINISH FLOOR  
 RADIANT TUBING SET IN GYP-CRETE

1" HIGH DENSITY POLYISO W/REFLECTIVE FOIL

1 1/2" X 3 1/2" STRAPPING @ 12" O.C.

SOUND DEADENING (HOMASOTE)

1 1/2" DECKING

JBOX  
 CONDUIT IN CAVITY

1/2" GWB W/1/8" PLASTER SKIM COAT  
 2X STRAPPING

5/8" WOOD STRIP

5/4" X 6" WOOD BASE (TYP)

1" FINISH FLOOR

DIAGONAL BOARD SUB-FLOOR  
 RADIANT TUBING SET IN GYP-CRETE

1 1/2" X 3 1/2" STRAPPING @ 12" O.C.

1" HIGH DENSITY POLYISO W/REFLECTIVE FOIL

1 1/2" DECKING

3" NOM. SPRAY FOAM INSULATION

1/2" GWB W/1/8" PLASTER SKIM COAT

2X3 BLOCKING

TOP BLOCK TAPERED TO ALLOW CONCRETE BEARING FOR ABOVE GRADE WALLS

#4 @ 12" O.C.  
 #5 @ 12" O.C. VERT.

NOTE: MAXIMUM STONE VENEER HEIGHT NOT TO EXCEED 48"

2"x4" WOOD STUD SOFFIT

DATION DETAIL  
 SEALANT

4" REINFORCED CONC. SLAB

1/2" INSULTARP-TAPE ALL JOINTS- TURN UP & SEAL @ FOUNDATION WALL

8" MIN. CRUSHED STONE UNDER VAPOR BARRIER